

CLIENT INFORMATION: ALUPROF SA
Warszawaka 153 Street
Bielsko-Biala, 43-300, Poland

TEST LABORATORY: Molimo, LLC
1410 Eden Road
York, Pennsylvania 17402
717-900-6034

PROJECT SUMMARY:

PRODUCT TYPE: XO Sliding Glass Door

SERIES/MODEL: MB-37 Slide Storm (SGP)

PROJECT SUMMARY:

Molimo, LLC was contracted to perform testing on the above referenced product. Testing was conducted using Test Protocols TAS 201, TAS 202, and TAS 203 in accordance with the Florida Building Code for the High Velocity Hurricane Zone. The specimens tested met the performance requirements set forth in the referenced test protocols. The test results are summarized in the table below.

Specimen #	Test Protocol	Design Pressure
1	TAS 202	+100 / -100 psf
2	TAS 201 / TAS 203 (Large Missile)	+100 / -100 psf
3	TAS 201 / TAS 203 (Large Missile)	+100 / -100 psf
4	TAS 201 / TAS 203 (Large Missile)	+100 / -100 psf

PROJECT DETAILS:

Test Dates: 8/24/2023 – 10/3/2023

Test Record Retention End Date: 10/3/2033

Test Location: Molimo, LLC test facility in York, Pennsylvania.